

**From:** [Christian Dano](#)  
**To:** [Lara Davis](#)  
**Cc:** [Colleen Stansfield](#); [Andrew Puntini](#)  
**Subject:** 250 Turnpike road 40 b  
**Date:** Thursday, February 20, 2025 11:41:56 AM

---

Hi Lara,

I met with the chief this am to figure out the best way to have access and turn around for fire apparatus at the above location. We came up with some options.

- We would like to see a proposed access road for emergency vehicles.
- The cul-de-sac at the end, instead of doing plantings we want most of it to be cobbled stone or some type of surface that our ladder truck and drive on to make it easier to turn around.
- Another proposal would be an area (possibly between 26 and 27?) for an area that we could back into to turn around so we aren't backing onto Turnpike Road.

I will send you a revised site plan review that I had sent to the Planning board that reflect the concerns that the peer review brought forward.

Thank you,

Chris

"The two most important days of your life are the day you were born and the day you find out why." Mark Twain